

Questions & Answers
Clifton Service Center
54618-9999-04
03-42-259998

Question: Bid states bidders should assume 800 tons of soil for excavation and disposal. Should bidders provide a unit rate for excavation and landfill/treatment as well?

Answer: A unit rate was not required in the bid specification.

Question: Will Commerce adjust the cap downward for quantities excavated less than the 800 tons?

Answer: Yes.

Question: Will shoring be required of the excavation near CTH A or will the use of proper sloping as determined by a Competent Person be adequate?

Answer: Bidders will coordinate the excavation with the Town of Clifton Highway Department. Shoring is not anticipated. However, if shoring is required by the Town the winning bidder will contact both DNR and Commerce with the Townships requirements and the cap will be adjusted appropriately.

Question: What is the depth of MW-7?

Answer: MW-7 is 16 feet below ground surface and is screened from 6-16 feet.

Question: The bid states quarterly groundwater monitoring should be performed on all wells in the network. Does this include the three piezometers?

Answer: Yes.